



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on February 15, 2011.

ARI Flow Control Accessories
Kibbutz Kfar Charuv 12932
Israel
972 6 676 1980

Facility: Kibbutz Kfar Charuv, Israel

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Backflow Preventers [G]			
DC 500	1/2" - 2"	CLD 23	MLTPL
RP 500	1/2" - 2"	CLD 23	MLTPL
Valves [G]			
D-040 C BARAK	1/2" - 2"	CLD 23	MLTPL
D-040 St.St.	1/2" - 2"	CLD 23	MLTPL
D-040 U BARAK	1/2" - 2"	CLD 23	MLTPL
D-060 HF	2" - 10"	CLD 23	MLTPL
D-060 HF NS	2" - 10"	CLD 23	MLTPL
D-060-C HF	2" - 10"	CLD 23	MLTPL
D-060-C HF NS	2" - 10"	CLD 23	MLTPL
D-062 HF	2" - 10"	CLD 23	MLTPL
D-062 HF NS	2" - 10"	CLD 23	MLTPL
K-060 HF	2" - 10"	CLD 23	MLTPL
K-060 HF NS	2" - 10"	CLD 23	MLTPL
S-050 St.St.	1/2" - 1"	CLD 23	MLTPL
S-050 U SEGEV	1/2" - 1"	CLD 23	MLTPL
S-050-C	1/2" - 1"	CLD 23	MLTPL
S-052	1/2" - 1"	CLD 23	MLTPL

[G] Product also Certified to NSF/ANSI 61, Annex G and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193. Weighted average lead content <=0.25%; Solder and flux lead content <=0.2%.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.